

081000 Doors and Frames

Sections Included In this Standard:

- 1.1 General
- 1.2 Doors
- 1.3 Frames

1.1 GENERAL

- A. **DISABLED ACCESS:** Comply with the requirements of ACCESS FOR PERSONS WITH DISABILITIES (Appendix B).
- B. **RENOVATIONS:** In renovations of existing buildings, door finish and style shall be in keeping with existing doors that remain. Doors along hallways shall be uniform in appearance. New door hardware shall match the existing.

1.2 DOORS

- A. **INTERIOR:** All typical interior hinged doors shall be solid core, hardwood veneer. Hollow core or formica-covered doors are not acceptable.
- B. **EXTERIOR:** Exterior doors shall be insulated and galvanized solid core flush steel.
 - a. Unless desired to have exterior doors stay as a galvanized finish, they shall be primed from the factory.
 - b. Shall have continuous welded seams.
- C. **FIRE RATED:** Fire rated doors and frames shall have appropriate UL labels.
- D. **STOREFRONT:**
 - 1. Door hardware for aluminum storefront shall be the same quality as that described in Section 08700. The storefront manufacturer's standard door hardware is not acceptable unless it can be shown to match the quality of hardware described in Section 08700. Installations as such require approval to be obtained by the Project Manager through the submission of a Standards Project Deviation Request Form.

1.3 FRAMES

- A. Frames shall be hollow metal, fully welded along entire depth.
- B. Knockdown frames are acceptable only in renovation projects, with prior written approval by Facilities Services UF Project Manager.
- C. Exterior hollow metal frames shall be galvanized. Exception – historical buildings.

END OF SECTION