132100 Controlled Environment Rooms

1.1 WALK-IN COLD ROOMS

- A. Refrigeration Systems:
 - 1. Specify water- cooled condensers only.
 - 2. Connect supply and return piping to the building chilled water supply and return system.
 - 3. Provide emergency back-up connection to the domestic water system, utilizing the appropriate combination of valves and double check valves for backflow prevention.

END OF SECTION